

## Condition Based Maintenance

**Byron A. Ellis**

*Consultant and Executive Director of The Jethro Project, (TJP), email: [ellis@jethroproject.com](mailto:ellis@jethroproject.com).*

### ***Abstract***

A well-implemented condition based maintenance (CBM) regime requires management support, data analysis to determine cost-effective monitoring points, and a knowledgeable and disciplined maintenance organization. The main objective of CBM is to ensure that assets fulfill their mission in the most cost-effectively manner.

*Keywords:* Condition based maintenance, reliability centered maintained, preventive maintenance, failure mode, computerized maintenance management system.

### ***Introduction***

Condition based maintenance (CBM) is a management philosophy that posits repair or replacement decisions on the current or future condition of assets (Raheja, Llinas, Nagi, & Romanowski, 2006); it recognizes that change in condition and/or performance of an asset is the main reason for executing maintenance (Horner, El-Haram, & Munns, 1997). Thus, Horner et al. noted that the optimal time to perform maintenance is determined from actual monitoring of the asset, its subcomponent, or part. They also noted that condition assessment varies from simple visual inspections to elaborate automated inspections using a variety of condition monitoring tools and techniques.

The objective of CBM is to minimize the total cost of inspection and repairs by collecting and interpreting intermittent or a continuous data related to the operating condition of critical components of an asset (Knapp and Wang, 1992). Knapp, Javadpour, and Wang (2000) argued that monitoring, where cost-effective, could provide adequate notice on pending failures, which would allow for planned repairs based on asset degradation, as

opposed to costly time-based (fixed intervals) repairs or emergency breakdowns. In some instances, however, CBM might not be cost-effective or data might not exist to justify its introduction.

Raheja, Llinas, & Nagi (2000), on the other hand, argued that current approaches to CBM system design are extremely specific and that a generic architecture for CBM is missing. Thus, they claimed that each domain area has its own interpretation of CBM that may not be compatible with the requirements of other applications. However, CBM is not applicable to all maintenance assets and should only be applied to instances where condition-monitoring techniques are available and cost-effective (Horner et al., 1997).

CBM requires robust analysis of reliability and financial maintenance data (Crespo Márquez & Sánchez Herguedas, 2004). Furthermore, it requires an unambiguous understanding of failure modes and rates, asset criticality, and potential payoffs associated with different maintenance strategies. Moubray (2001) cited studies done on civil aircraft describing patterns of failure that contradicted the belief of a relationship

between reliability and operating age. He noted that this belief led to the idea that frequent overhaul of an asset would increase its reliability.

According to Moubray (2001), unless there is a dominant age-related failure mode, time-based overhauls do not improve the reliability of complex items. He further noted that it is highly possible that time-based overhauls would introduce infant mortality failures in otherwise stable systems.

### ***The Benefit of Monitoring Asset Performance***

Wood (1999), as well as Moubray (2001), argued that time-based preventive maintenance (PM) often failed to maximize the service life of each component; in many instances the components were being replaced with many hours of useful life remaining. PM tasks, based on hard time intervals, waste a lot of resources (Tsang, 1995); that is, often the plant or building is over-maintained (Mann, Saxena, & Knapp, 1995).

Bloch and Geitner (1983), noted that certain signs, conditions, or indications precede 99% of all machine failures. Therefore, by monitoring an asset, action can be taken prior to it having a serious effect on the performance of the organization. Thus, condition-based monitoring offers an alternative to the PM assumption of age-related failure mode. Moreover, with condition-based monitoring, managers can focus on just-in-time (JIT) replacement. According to Wood, JIT replacement maximizes the life of each component and is facilitated by building automation systems (BAS) or intelligent buildings.

### ***Maintenance Strategies***

Coetzee (1999) observed that maintenance management often implement some highly publicized strategy towards increasing the efficiency of the maintenance function, such as reliability centered maintenance (RCM), total productive maintenance (TPM), condition based maintenance (CBM), computerized maintenance management systems (CMMS), auditing systems and so on. However, most managers do not know what the right regime for optimizing maintenance is. As a result, most efforts do not materialize.

Intervention strategies are not only technical in nature; they are also a matter of art (Heckscher, Eisenstat, & Rice, 1994). According to Hecksher et al. most best practice strategies fail within a year or so. They labeled this phenomenon as *successful failure*, which results from limited know-how within the organization: few internal members understanding what they are moving towards when they start an implementation process (Heckscher, et al.).

As a result, Coetzee (1999) argued for a holistic approach within the maintenance function to implement CBM. A holistic approach would include the evaluation of the maintenance assets, including building structures. Shonet (2003) argued that effective implementation of CBM requires the development of performance indicators for building components and systems. He noted that the evaluation of building components should assess (1) the physical performance of building systems, (2) frequency of failures of building systems, and (3) actual preventive maintenance (PM) carried out on the systems.

Likewise, a holistic approach should also include performance measurement systems as a tool for delivering strategic objectives, such as the implementation of a balanced scorecard process (Letza, 1996); the evaluation of breakdown (BD) maintenance, where the run to failure philosophy prevails; the evaluation of planned schedule maintenance, where planning and scheduling methodologies are rigorously applied; and the evaluation of CBM, where critical and costly assets are monitored for degradation (Amari and McLaughlin, 2004). Degradation is a process where system parameters gradually worsen.

The application of CBM requires the use of certain analytical tools, such as failure mode, effect, and criticality analysis (FMECA) and RCM to determine the likelihood of failure and how failure would occur; as well as a reliable information tool (i.e., CMMS) to capture and track repairs and associated costs of the assets under consideration.

FMECA is a systematic process for identifying all possible ways in which failures of an element can occur and RCM is an approach for identifying the most applicable and cost effective maintenance task for asset elements (El-Haram & Horner, 2002). Thus, El-Haram and Horner noted that the RCM process evaluates each failure to determine its consequences, if any, as well as each consequence to determine applicable and cost effective maintenance tasks.

Failure is when an asset, component or element cannot fulfill its mission. For many assets, however, certain symptoms (soft faults) often occur prior to total failure, such as excessive vibration, abnormal heat (Knapp et al., 2000), solid

contents in oil, and so on. Sensors capable of detecting pre-failure signals can provide alerts and alarms notifying the asset operator of the potential of an impending failure. For other assets, failure (hard faults) may occur instantaneously and cannot be predicted; generally these failures are exogenously generated.

CBM is a non-intrusive technique and the actual preventive action (repair) is taken at the incipient failure level (Tsang, 1995). Tsang noted that hidden failures are often present in standby units, protective devices, or infrequently used assets. Hidden failures are not evident until the time when the proper function of the item is needed.

Thus, a CBM regime on standby units, such as protective devices, or infrequently used assets would not be effective, since upon startup hidden failures could occur. However, to counteract, hidden failures Tsang (1995) recommended faultfinding (FF) tasks. FF tasks are performed at scheduled intervals to check the state of assets or items with dormant functions. A typical example is an emergency generator that is generally idle until needed.

According to Sherwin and Al-Najjar (1999) if downtime is very expensive, inspection and condition monitoring are not the best overall maintenance policies unless the combined age to failure distribution of the various failure modes of an asset, or component, has a large variance such that the standard deviation is greater than or (nearly) equal to the mean.

### ***Determining CBM Failure Point***

Determining when a failure mode has been initiated and predicting the time remaining for complete failure requires reliable data and effective algorithms. Moreover, making decisions on the appropriate maintenance response to CBM alerts or alarms requires a disciplined maintenance organization.

Many maintenance organizations equipped with CBM do not effectively respond to alerts and alarms. However, some CBM systems are integrated into the CMMS, so that a work order is automatically generated when signals from a monitored point trigger alerts or alarms. This is particularly suited for continuous process plants where failure and downtime can be extremely costly.

### ***False Alarms***

A key requirement for successful implementation of CBM is a low incidence of false alarms and quick and reliable detection of faults (Buswell & Wright, 2004). Buswell and Wright noted that an International Energy Agency (IEA) project indicated that abrupt faults could be easily detected; degradation faults, on the other hand, had to be quite large before detection was unambiguous. The study also noted that it is possible to balance robustness and sensitivity. Increasing sensitivity results in early warning of faults, but may increase the incident of false alarms (Knapp, Javadpour, & Wang, 2000). However, condition-based monitoring industry leaders have applied quality control type techniques in the detection of machine faults; thus, providing increased protection from false alarms, as well as from missed faults (Mann et al., 1995).

### ***Conclusion***

The introduction of CBM without managerial support at all levels, appropriate data and analysis, a disciplined and knowledgeable maintenance staff is unlikely to achieve desired results.

---

**Copyright of TJP is the property of The Jethro Project and its contents may not be copied or emailed to multiple sites or posted to a listserver without the copyright holder's express written permission. User, however, may print, download, or email articles for individuals use.**

---

## References

- Amari, S.V & McLaughlin, L. (2004). Optimal design of condition based maintenance Model. IEEE.
- Brian W. (1999). *Intelligent building care, Facilities*, Volume 17 · Number 5/6 , pp. 189–194.
- Buswell, R. A., & Wright, J. A. (2004). Uncertainty in model-based conditioning monitoring. *Building Services Engineering Res. Technol*, 25 (1), 65-75.
- Coetzee, J.L. (1999). A holistic approach to the maintenance ``problem." *Journal of Quality in Maintenance Engineering*, Vol. 5 No. 3, pp. 276-280.
- El-Haram, M.A., and Horner, R.M.W. (2002). *Journal of Quality in Maintenance Engineering*, Vol. 85 No.2, pp. 135-143.
- Heckscher, C., Eisenstat, R. A., & Rice, T. J. (1994). Transformational processes. In C. Heckscher and A. Donnellon (Eds.), *The post-bureaucratic organization: New perspectives on organizational change* (pp. 129-177). Thousand Oaks, CA: Sage Publications.
- Horner, R.M.W., El-Haram, M.A., and A.K. Munns (1997). Building maintenance strategy: a new management approach, *Journal of Quality in Maintenance Engineering*, Vol. 3 No. 4, pp. 273-280.
- Knapp, G.M. and Wang, H.P. (1992), ``Machine fault classification: a neural network approach," *International Journal of Production Research*, Vol. 30 No. 4, pp. 811-23.
- Knapp, G.M., Javadpour, R., and Wang, H.P. (2000), An ARTMAP neural network-based machine condition monitoring system. *Journal of Quality in Maintenance Engineering*, Vol. 6 No. 2, 2000, pp. 86-105.
- Stephen R. Letza (1996). The design and implementation of the balanced business scorecard. *Business Process Re-engineering & Management Journal* Vol. 2 No. 3, 54-76.
- Moubray, J (2001). Reliability-Centered Maintenance. NY: NY Industrial Press Inc.
- Raheja, D., Llinas, J., Nagi, R. & Romanowski, C. (2000). A holistic view of condition based maintenance. Working Paper, December 2000 (Center for Multisource Information Fusion (CMIF), SUNY).
- Raheja, D., Llinas, J., Nagi, R. & Romanowski, C. (2006). Data fusion/data mining based on architecture for condition based maintenance. *International Journal of Production Research*,
- Shonet, I.M. (2003). Building evaluation methodology for setting maintenance priorities in hospital buildings. *Construction Management and Economics*
- Tsang, A. C. (1995). Condition based maintenance: Tools and decision making. *Journal of Quality in Maintenance Engineering*, 1(3), 1-17.